



## City of Santa Clara

Building Division  
1500 Warburton Ave.  
Santa Clara, CA 95050  
www.santaclaraca.gov

Building Division: 408-615-2440  
Email: Building@santaclaraca.gov


Permit Center: 408-615-2420  
Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

## 2016 CALIFORNIA BUILDING CODE - SECTION 11B-403 GENERAL REQUIREMENTS FOR WALKS & SIDEWALKS

### ❖ **Width:** 48" minimum (CBC 11B-403.5.1 Exception 3)

Exception: The clear width can be reduced to 36" for right-of-way restrictions, natural barriers or other existing conditions.



### ❖ **Walking Surface:** Shall be stable, firm, and slip resistant (CBC 11B-302)

### ❖ **Slope:** does not exceed 1:20 slope (5%) in the direction of travel. Cross slope shall not be steeper than 1:48 (2.1%). CBC 11B-403.3

### ❖ **Change in Level:** (CBC 11B-303.3)

- Vertical changes in level do not exceed 1/4".
- Level change between 1/4"-1/2" are beveled with a maximum slope of 1:2

### ❖ **Opening in Floor or Ground Surfaces:** (CBC 11B-302.3)

Shall not allow passage of a sphere more than 1/2" diameter. Elongated openings shall be placed so that the long dimension is perpendicular to the direction of travel.



FIGURE 11B-303.2  
VERTICAL CHANGE IN LEVEL




FIGURE 11B-303.3  
BEVELED CHANGE IN LEVEL




FIGURE 11B-302.3  
ELONGATED OPENINGS IN FLOOR OR GROUND SURFACES



## City of Santa Clara

Building Division  
1500 Warburton Ave.  
Santa Clara, CA 95050  
www.santaclaraca.gov

Building Division: 408-615-2440  
Email: Building@santaclaraca.gov

Permit Center: 408-615-2420  
Email: PermitCenter@santaclaraca.gov

Automated Inspection Scheduling System: 408-615-2400

## 2016 CALIFORNIA BUILDING CODE - SECTION 11B-403 GENERAL REQUIREMENTS FOR WALKS & SIDEWALKS

### ❖ **Passing Spaces:** (CBC 11B-403.5.3)

Accessible routes with less than 60" of clear width shall provide a min 60" x 60" or T-shaped passing space at least every 200' maximum.

### ❖ **Resting Areas:** (CBC 11B-403.7)

All walks with continuous gradients shall have resting areas, 60" in length, at intervals of 400' maximum. The resting area shall be at least as wide as the walk with 1:48 max. slope in all directions.

